

City of Albuquerque

City of Albuquerque Government Center One Civic Plaza Albuquerque, NM 87102

Legislation Details (With Text)

File #: O-11-52

Type: Ordinance Status: Enacted and Published

File created: 3/21/2011 In control: City Council

Final action: 4/18/2011

Title: Amending The City Of Albuquerque Fire Code Ordinance O-2005-034 Chapter 9 Section 903.2.1.2

That Requires Existing A-2 Assembly Occupancies With A Fire Area Exceeding 5,000 Square Feet, Or With An Occupant Load Exceeding 300 Persons, Or With A Fire Area Located On A Floor Other Than

The Level Of Exit Discharge, To Install A Fire Sprinkler System And Required Alarm System;

Authorizing Such Existing A-2 Occupancies Additional Time For Submission Of Plans And Installation

Of Such Systems (Winter)

Sponsors: Brad Winter

Indexes:

Code sections:

Attachments: 1. O-52.pdf, 2. O-52final.pdf

Date	Ver.	Action By	Action	Result	
5/9/2011	1	City Clerk	Published		
5/6/2011	1	Mayor	Signed by the Mayor		
4/26/2011	1	City Council	Sent to Mayor for Signature		
4/18/2011	1	City Council	Do Pass	Pass	
4/18/2011	1	City Council	Accepted with a Recommendation Do Pass (Immediate Action)		
4/11/2011	1	Finance & Government Operations Committee	Sent to Council with a recommendation of Do Pass	Pass	
4/11/2011	1	Finance & Government Operations Committee	Sent to Council for Immediate Action	Pass	
3/21/2011	1	President	Referred		
3/21/2011	1	City Council	Introduced and Referred		

CITY of ALBUQUERQUE

NINETEENTH COUNCIL

OUNCIL BILL NO	O-11-52	ENACTMENT NO.	

SPONSORED BY: Brad Winter

ORDINANCE

Amending The City Of Albuquerque Fire Code Ordinance O-2005-034 Chapter 9 Section 903.2.1.2 That Requires Existing A-2 Assembly Occupancies With A Fire Area Exceeding 5,000 Square Feet, Or With An Occupant Load Exceeding 300 Persons, Or With A Fire Area Located On A Floor Other Than The Level Of Exit Discharge, To Install A Fire Sprinkler System And Required Alarm System; Authorizing Such Existing A-2 Occupancies

Additional Time For Submission Of Plans And Installation Of Such Systems (Winter) AMENDING THE CITY OF ALBUQUERQUE FIRE CODE ORDINANCE O-2005-034 CHAPTER 9 SECTION 903.2.1.2 THAT REQUIRES EXISTING A-2 ASSEMBLY OCCUPANCIES WITH A FIRE AREA EXCEEDING 5,000 SQUARE FEET, OR WITH AN OCCUPANT LOAD EXCEEDING 300 PERSONS, OR WITH A FIRE AREA LOCATED ON A FLOOR OTHER THAN THE LEVEL OF EXIT DISCHARGE, TO INSTALL A FIRE SPRINKLER SYSTEM AND REQUIRED ALARM SYSTEM; AUTHORIZING SUCH EXISTING A-2 OCCUPANCIES ADDITIONAL TIME FOR SUBMISSION OF PLANS AND INSTALLATION OF SUCH SYSTEMS.

BE IT ORDAINED BY THE COUNCIL, THE GOVERNING BODY OF THE CITY OF ALBUQUERQUE:

SECTION 1. Chapter 9 Section 903.2.1.2 is amended to read as follows:

"Group A-2. An automatic sprinkler system and required alarm system shall be provided for all Group A-2 occupancies where one of the following conditions exists:

- 1. The fire area exceeds 5,000 square feet (464.5m²);
- 2. The fire area has an occupant load of 300 or more; or
- 3. The fire area is located on a floor other than the level of exit discharge.

By July 28, 2011, all owners of buildings that fall within the scope of these requirements shall have fire sprinkler plans submitted to the Fire Marshal's Office Plans Review Section for review and approval. By July 28, 2012, every building falling within the scope of these requirements shall be in compliance, unless such building undergoes a repair, alteration or remodel of more than 50 percent of the aggregate square footage of the building or submits for an increase in the posted occupant load prior to the compliance date."

SECTION 2. SEVERABILITY CLAUSE. If any section, paragraph, sentence, clause, word or phrase of this ordinance is for any reason held to be invalid or unenforceable by any court of competent jurisdiction, such decision shall not affect the validity of the remaining provisions of this ordinance. The Council hereby declares that it would have passed this ordinance and each section, paragraph, sentence, clause, word or phrase

